

## EXECUTIVE SUMMARY

### Introduction

1. This is the 36<sup>th</sup> Environmental Monitoring and Audit (EM&A) Report prepared by Cinotech Consultants Limited for the “Contract No. KLN/2013/16 - Environmental Monitoring Works for Kai Tak Development” (hereinafter called “the Project”). This report documents the findings of EM&A Works conducted in February 2017.
  
2. During the reporting month, the following works contracts were undertaken within Kai Tak Site:
  - 1020EM12A - District Cooling System (DCS) at Kai Tak Development (KTD) Phase III (Package A)-Chilled Water Pipe Laying Works
  - 2477EM14A - District Cooling System (DCS) at Kai Tak Development (KTD) Phase III (Package B)-Water Pipe Laying Works
  - 2487EM14W - District Cooling System (DCS) at Kai Tak Development (KTD) Phase III (Package B)-Electrical and Mechanical Installation
  - 1107 - MTR Shatin to Central Link: Diamond Hill to Kai Tak Tunnels
  - 1108 - MTR Shatin to Central Link: Kai Tak Station and Associated Tunnels
  - 1109 - MTR Shatin to Central Link: Ma Tau Wai and To Kwa Wan Stations and Tunnels
  - 1123 - MTR Shatin to Central Link: Exhibition Station and Western Approach Tunnel
  - 20150362 - Construction of Home Ownership Scheme at Kai Tak Site 1G1(B)
  - 3/WSD/08, 6/WSD/08, 7/WSD/08 & 8/WSD/08 - Replacement and Rehabilitation of Water Mains Stages 2 & 3
  - DC/2011/04 - Reconstruction, Improvement and Rehabilitation of Kai Tak River from Wong Tai Sin Police Station to Tung Tau
  - KL/2011/01 - Kai Tak Development –Reconstruction and Upgrading of Kai Tak Nullah
  - KL/2012/02 - Kai Tak Development – Stage 3A Infrastructure at Former North Apron Area
  - KL/2012/03 - Kai Tak Development – Stage 4 Infrastructure at Former North Apron Area
  - KL/2014/01 - Kai Tak Development - Stage 2 Infrastructure Works for Developments at the Southern Part of the Former Runway
  - KL/2014/03 - Kai Tak Development - Stage 3 Infrastructure Works for Developments at the Southern Part of the Former Runway
  - KL/2015/02 - Kai Tak Development – Stage 5A Infrastructure at Former North Apron Area
  - KL/2015/03 – Kai Tak Development – Stage 3B Infrastructure at Former North Apron Area
  - New Kowloon Inland Lot No. 6516 & 6517 - Proposed Residential Development
  - New Kowloon Inland Lot No. 6525 - Residential Development at Kai Tak Area 11 Site 1
  - New Kowloon Inland Lot No. 6526 - Residential Development at Kai Tak Area 11 Site 2
  - New Kowloon Inland Lot No. 6527 - Residential Development at Kai Tak Area 11 Site 3

- New Kowloon Inland Lot No. 6541 - Residential Development at Kai Tak Area 1H Site 3
  - SS A501 - Design and Construction of Centre of Excellence in Paediatrics
  - SS E517 – Construction of a 30-classroom Secondary School at Kai Tak Development, Kowloon (Site 1A-2)
  - SS C503 – Design and Construction of Kowloon East Regional Headquarters and Operational Base cum Ngau Tau Kok Divisional Police Station at 105 Concorde Road, Kai Tak
  - HY/2014/18 – Provision of Barrier-Free Access Facilities for Highway Structures – Phase 3 Contract 7
3. Stockpiling of excavated & construction materials, storage of equipments, business in the recovery and recycling and car parks, etc are the major activities for short term tenancy (STT) / temporary government land allocation (TGLA).

**Environmental Monitoring Works**

4. Environmental monitoring for the Project was performed in accordance with the EM&A Manual and the monitoring results were checked and reviewed. Site Inspections/Audits were conducted once per week. The implementation of the environmental mitigation measures, Event Action Plans and environmental complaint handling procedures were also checked.
5. Summary of the non-compliance in the reporting month for the Project is tabulated in Table 1.

**Table 1 Non-compliance Record for the Project in the Reporting Month**

Parameter	No. of Exceedance		Action Taken
	Action Level	Limit Level	
1-hr TSP	0	0	N/A
24-hr TSP	0	0	N/A
Noise	0	0	N/A

Remark: No complaint concerning construction noise was received in the time period of 0700 – 1900 hrs on normal weekdays.

***1-hour & 24-hour TSP Monitoring***

6. All 1-hour TSP monitoring was conducted as scheduled in the reporting month. No Action/Limit Level exceedance was recorded.
7. All 24-hour TSP monitoring was conducted as scheduled in the reporting month. No Action/Limit Level exceedance was recorded.
8. The air quality monitoring results in February 2017 are presented in Table 2.

**Table 2 Air Quality Monitoring Results in February 2017 Monitoring Station**

Monitoring Station	Description	1-hour TSP ( $\mu\text{g}/\text{m}^3$ )	24-hour TSP ( $\mu\text{g}/\text{m}^3$ )
AM1(B)	Outside Arup site office (KL/2012/02)	156 (84 - 222)	54 (35 - 77)
AM2	Lee Kau Yan Memorial School	150 (76 - 244)	48 (24 - 80)
AM3(A)	Holy Trinity Bradbury Centre	156 (99 - 254)	71 (47 - 100)
AM4(B)*	Ma Tau Kok Road (next to EMSD workshops)	165 (100 - 211)	N/A
AM5(A)	Po Leung Kuk Ngan Po Ling College	141 (85 - 190)	35 (22 - 45)
AA1	Ching Long Shopping Centre	110 (38 - 184)	47 (24 - 61)
AA2	Tak Long Estate	109 (47 - 186)	101 (45 - 132)

\* Remark: Air monitoring station, AM4(A) - EMSD Workshops, had been inaccessible since late December 2016 due to demolition works. 1-TSP monitoring was conducted temporarily at AM4(B) - Ma Tau Kok Road (next to EMSD workshops) while 24-TSP monitoring had been pending due to rejection from nearby building owners regarding the request on setting up the monitoring station at their premises. The ET is proposing the boundary of CEDD contract no.KL/2012/03 nearby as the alternative.

### **Construction Noise**

9. All construction noise monitoring was conducted as scheduled in the reporting month. No Action/Limit Level exceedance was recorded.
10. The noise monitoring results in February 2017 are presented in Table 3.

**Table 3 Noise Monitoring Results in February 2017 Monitoring Station**

Monitoring Station	Description	Allowable Noise Level Leq (30min) dB (A)	Noise Level Leq (30min) dB (A)
M1	Buddhist Chi King Primary School	70	51 - 64
M2	SKH Kowloon Bay Kei Lok Primary School	70	63 - 68
M3	Rhythm Garden	76.3	66 - 72
M4	Cognitio College	79	64 - 70
M5	Lee Kau Yan Memorial School	76.7	60 - 76
M6(C)*	Mercy Grace's Home	78	66 - 77
M7(A)	Oblate Primary School	70	59 - 62

Monitoring Station	Description	Allowable Noise Level Leq (30min) dB (A)	Noise Level Leq (30min) dB (A)
M8	CCC Kei To Secondary School	70	62 – 67
M9	Po Leung Kuk Ngan Po Ling College	70	60 – 70
M10	Tak Long Estate	75	60 – 65
MA1	Ching Long Shopping Centre	75	63 – 66

\* Remark: Noise monitoring was temporarily conducted at M6(B), HK Deaf People Christian Church and M6(C), Mercy Grace's Home due to rejected access from M6(A) Kowloon City District Kai-Fong Welfare Association starting from mid-October 2016. The ET subsequently proposed M6(C) as the alternative noise monitoring station for M6(A) in early November 2016. The IEC expressed no further comment on the proposal.

### Key Information in the Reporting Month

11. Summary of key information in the reporting month is tabulated in Table 4.

**Table 4 Summary Table for Key Information in the Reporting Month**

Event	Event Details		Action Taken	Status	Remark
	Number	Nature			
Complaint received	4	Construction Dust and Construction Noise	Investigation was conducted by the Contractor	Closed	---
Reporting Changes	0	---	N/A	N/A	---
Notifications of any summons & prosecutions received	2	Non-compliance of discharge requirement under WPCO	Summon was issued to the contractor on 17 February 2017	Schedule for Trail	MTR Contract No. 1108
		Non-compliance of Construction Noise Permit under NCO	Summon was issued to the contractor on 24 February 2017	Convicted	K. Wah International Contract No. NKIL6526

### Future Key Issues

12. The future key environmental issues in the coming month include:
- Dust generation from stockpiles of dusty materials, exposed site area, excavation works and rock breaking activities;
  - Watering for dust generating activity and on haul road;
  - Proper storage of construction materials on site;
  - Storage of chemicals/fuel and chemical waste/waste oil on site;
  - Accumulation of general and construction waste on site;

- Noise from operation of the equipment, especially for rock-breaking activities, piling works and machinery on-site;
- Runoff from exposed slope;
- Wastewater and runoff discharge from site;
- Regular removal of silt, mud and sand along u-channels and sedimentation tanks; and
- Review and implementation of temporary drainage system for the surface runoff.

THE FULL VERSION EM&A REPORT FOR FEBRUARY 2017 CAN BE VIEWED FROM THE ARCHIVED REPORT